

**RESOLUTION NO. CC-2011-15; SUA-2011-10**

**“A RESOLUTION AMENDING THE CITY OF STILLWATER TERMS AND CONDITIONS OF SERVICE BY ESTABLISHING SPECIAL WATER SERVICE RULES FOR THE TWIN TOWERS SERVICE AREA LOCATED WITHIN THE RWC#3 SERVICE AREA.”**

**WHEREAS**, the City of Stillwater/Stillwater Utilities Authority is the owner and operator of the Payne County Rural Water Corporation #3 (RWC#3) potable water distribution system; and

**WHEREAS**, said system includes all storage and pumping facilities acquired by the City of Stillwater/Stillwater Utilities Authority in January 2007; and

**WHEREAS**, the City of Stillwater/Stillwater Utilities Authority, as the owner and operator of the RWC#3 rural water distribution system, is required by Oklahoma Department of Environmental Quality regulations to maintain certain minimum standards of design, construction, operation, maintenance and provision of service; and

**WHEREAS**, the adopted “Terms and Conditions of Service” establishes the rules and regulations for utility services provided by the City of Stillwater/Stillwater Utilities Authority; and

**WHEREAS**, the City of Stillwater/Stillwater Utilities Authority established rural water service rules for the RWC#3 service area by amendment of the “Terms and Conditions of Service” in August of 2010; and

**WHEREAS**, a portion of the RWC#3 service area served by the “Boersma Pump Station” and the “Twin Towers,” commonly known as the “Twin Towers Service Area,” has been recently evaluated; and

**WHEREAS**, the physical condition of the water distribution system in the Twin Towers Service Area will not accommodate any additional water connections (taps) in accordance with the criteria contained in the “Terms and Conditions of Service”; and

**WHEREAS**, amendment of said Terms and Conditions of Service is necessary to accommodate continued growth in the Twin Towers Service Area.

**NOW, THEREFORE, BE IT RESOLVED BY THE CITY COUNCIL OF THE CITY OF STILLWATER, OKLAHOMA AND THE TRUSTEES OF THE STILLWATER UTILITIES AUTHORITY:**

**SECTION 1:** Section VI of the “Terms and Conditions of Service” entitled “Rural Water Service Rules, RWC#3 Service Area” is hereby amended as follows:

Section 6.1.3. WATER SERVICE RULES, subsection A. “Ability to Serve-Special Provisions for the Twin Towers Service Area” shall read:


1. All undeveloped parcels and platted lots that existed on July 18, 2011 and are located immediately adjacent to a previously installed water line extension that was accepted by the City of Stillwater or RWC#3 will be allowed one (1) domestic tap (3/4- or 1-inch meter). No other connections (taps), including additional connections for current customers, or upsizing of existing connections shall be permitted.
2. Connections (taps) to the water distribution system shall be discontinued if at any time it is determined (by modeling or by actual measurement) that the pressure in the Twin Towers Service Area distribution system may drop below 25 psi, under peak demand conditions.

PASSED, APPROVED, AND ADOPTED this 7th day of November 2011.

CITY OF STILLWATER, OKLAHOMA  
A Municipal Corporation


STILLWATER UTILITIES AUTHORITY  
A Public Trust



  
MARCY ALEXANDER  
CITY CLERK/SECRETARY

  
NATHAN BATES  
MAYOR/CHAIRMAN

Approved as to form and legality this 7<sup>th</sup> day of November 2011.

  
JOHN E. DORMAN  
CITY ATTORNEY/GENERAL COUNSEL